

December 14, 2016

ADDENDUM 2
ONE PAGE

TO DRAWINGS AND SPECIFICATIONS FOR:

NIABI ZOO DESIGN/BUILD WATER TREATMENT PROJECT
13010 NIABI ZOO ROAD
COAL VALLEY, IL 61240

ADDENDA TO PROJECT MANUAL

This Addendum modifies the original Contract Documents and Project Manual dated December 1, 2016. Bidders must acknowledge receipt of the Addendum on the Bid Form.

Unless otherwise indicated, the work described herein shall comply with, and be equal in all respect to, the original Contract Specifications and Drawings, include all incidental work required to properly complete the work whether stated herein or not.

1. Update DOCUMENT 00 22 13 SUPPLEMENTARY INSTRUCTIONS TO BIDDERS, Page 00 22 13-1, Paragraph 3.1.1

3.1.1. Supplementary Instructions To Bidders:

- A) Replace the first sentence with the following: Prime Bidders may obtain complete sets of the bidding documents from CBT, 4657 44th St, Rock Island, Illinois upon depositing the sum of one twenty five dollars (\$25.00) for each set of documents.
2. Pre-Bid Meeting Questions:
 - A) Where will the R.O. system go?
 - The system will feed into a holding tank.
 - The tank will be provided and installed by the zoo.
 - No distribution will be involved.
 - The prime contractor will connect the R.O. system to the holding tank.
 - The R.O. system will be located in a closet in the jungle trek exhibit.
 - B) Will the prime be responsible for fixes to landscape damage from construction traffic at the animal hospital location?
 - No, the zoo will repair minor damage in house.